



City of Carlsbad, New Mexico
RFP # 2017-10
Addendum 1

4/27/17

Addendum Notice – Cavern City Air Terminal Entrance Improvements

The City of Carlsbad has been asked the following question in regards to Bid 2017-10 and offers the response in blue text:

The proposal states that the contractor will include electrical connection within 10ft of the final location of the sign. There are no electrical plans provided with this solicitation? Does this note mean that we will only be responsible for the last 10 feet of electrical connection or do we need to run power back to the Cavern City Air Terminal?

Only a power connection/hook up within 10 ft. of the sign is intended to be included in this bid. Sufficient electric power will be provided by the City to within 10 ft. of the sign's final location.

Matt Fletcher
Purchasing Manager
City of Carlsbad
575-234-7905

If you have any questions, please feel free to contact me at 575-234-7905 or email me at msfletcher@cityofcarlsbadnm.com.

Please return a signed copy of this addendum notice with your bid.

X _____
Name of Representative

Date: _____