

City of Carlsbad Notification Form for Municipal and Double Eagle Water System Pipeline Crossings

The City of Carlsbad requires that your planned crossing of our water pipeline be constructed according to standard City policy. Please take the time to fill out one of these forms for each single proposed crossing of City-owned water pipeline planned. After these forms are completed, please mail or deliver to City of Carlsbad Water Department Superintendent, PO Box 1569 (street address 1502 W. Stevens), Carlsbad, NM 88221-1569.

The City's policy on pipeline crossings exists for the protection of both our pipe and those who intend to cross them. The policy calls for either a ten-foot vertical separation beneath our line with an uncased pipe or a three-foot vertical separation beneath our line with a cased and vented line. The casing must consist of a minimum of twenty feet of steel (ten on each side of crossing) casing with a diameter of at least 2 inches larger than the product pipe. In addition, permanent markers must be placed on both side of the crossing and the City of Carlsbad request that the crossing occur to as close to a 90° angle as possible. Prior to the construction of the actual crossing, please contact the Water Department Superintendent at 885-6313. The City of Carlsbad appreciates your cooperation.

City of Carlsbad Notification Form for Municipal and Double Eagle Water System Pipeline Crossings

Company Name & Address: _____

Contact Person: _____ Phone Number: _____

Location of Proposed Crossing: ¼ of ¼: _____ Section: _____

Township: _____ Range: _____

Method of Crossing (Check one):

_____ 3 feet vertical separation with casing and vents

_____ 10 feet vertical separation without casing with permanent crossing markers installed on either side of crossing

For City of Carlsbad Use Only:

Crossing plan is _____ approved / _____ disapproved

Water Superintendent: _____

Comments:

Inspected by: _____

Final Approval: _____ yes _____ no

Water Superintendent: _____

Environmental Services Officer: _____

Utilities Director: _____