

City of Carlsbad Municipal Water System UCMR-5 Results

The City of Carlsbad Municipal Water System was sampled for a series of chemical constituents as required by the EPA's Unregulated Contaminant Monitoring Rule-5 (UCMR-5) program. The results from these sampling events are listed below. For more information you may contact the Water Department by calling (575) 885 - 6313 or sending an email to water@cityofcarlsbadnm.com					
	Results	Results	Results	Results	MRL
Analyte	March 2023 Entry Point East	March 2023 Entry Point West	Sept 2023 Entry Point East	Sept 2023 Entry Point West	Minimum Reporting Level
PFNA	< MRL	< MRL	< MRL	< MRL	0.004 ug/L
PFOA	< MRL	< MRL	< MRL	< MRL	0.004 ug/L
PFBS	< MRL	< MRL	< MRL	< MRL	0.003 ug/L
PFHxA	< MRL	< MRL	< MRL	< MRL	0.003 ug/L
PFHpA	< MRL	< MRL	< MRL	< MRL	0.003 ug/L
PFDoA	< MRL	< MRL	< MRL	< MRL	0.003 ug/L
PFHxS	< MRL	< MRL	< MRL	< MRL	0.003 ug/L
ADONA	< MRL	< MRL	< MRL	< MRL	0.003 ug/L
PFUnA	< MRL	< MRL	< MRL	< MRL	0.002 ug/L
PFTA	< MRL	< MRL	< MRL	< MRL	0.008 ug/L
11Cl-PF3OUdS	< MRL	< MRL	< MRL	< MRL	0.005 ug/L
9Cl-PF3ONS	< MRL	< MRL	< MRL	< MRL	0.002 ug/L
NMeFOSAA	< MRL	< MRL	< MRL	< MRL	0.006 ug/L
NEtFOSAA	< MRL	< MRL	< MRL	< MRL	0.005 ug/L
PFTTrDA	< MRL	< MRL	< MRL	< MRL	0.007 ug/L
4:2 FTS	< MRL	< MRL	< MRL	< MRL	0.003 ug/L
lithium	21 ug/L	< MRL	19.4 ug/L	< MRL	9 ug/L
8:2 FTS	< MRL	< MRL	< MRL	< MRL	0.005 ug/L
6:2 FTS	< MRL	< MRL	< MRL	< MRL	0.005 ug/L
PFBA	< MRL	< MRL	< MRL	< MRL	0.005 ug/L
PFPeA	< MRL	< MRL	< MRL	< MRL	0.003 ug/L
PFMPA	< MRL	< MRL	< MRL	< MRL	0.004 ug/L
PFHpS	< MRL	< MRL	< MRL	< MRL	0.003 ug/L
PFEESA	< MRL	< MRL	< MRL	< MRL	0.003 ug/L
PFPeS	< MRL	< MRL	< MRL	< MRL	0.004 ug/L
PFDA	< MRL	< MRL	< MRL	< MRL	0.003 ug/L
NFDHA	< MRL	< MRL	< MRL	< MRL	0.02 ug/L
PFOS	< MRL	< MRL	< MRL	< MRL	0.004 ug/L
HFPO-DA	< MRL	< MRL	< MRL	< MRL	0.005 ug/L
PFMBA	< MRL	< MRL	< MRL	< MRL	0.003 ug/L

ug/L = micrograms per liter < MRL = "less than the minimum reporting level"